



2021 HOSE TEST FAILURE RECORD

THE FOLLOWING LENGTHS FAILED DURING TESTING:

ID NUMBER	REASON	REPLACED YES/NO	REPLACED ID NUMBER
1031	Delamination	Yes	1017
1032	Leak @ male	Yes	1021
3001	Leak @ male	No	
4010	Pin Hole Leak	No	
5009	Multiple Leaks	No	
5011	Leak	No	

PLEASE NOTE THAT ALL LENGTHS THAT FAIL DURING TESTING SHOULD REMAIN OUT OF SERVICE UNTIL PROPERLY REPAIRED AND RETESTED!

AS PER NFPA 1962, ALL HOSE MANUFACTURED PRIOR TO JULY 1987 AND ALL LDH WITHOUT LOCKS MUST BE TAKEN OUT OF SERVICE!

IIA Fire Department Testing

PHONE: (732) 728-0739

FAX: (732) 656-0110

www.industrial-ia.com



2021 APPARATUS INVENTORY CONTROL SHEET

E-1	
DIAMETER (INCHES)	TOTAL LENGTH (FEET)
1 3/4"	950
2 1/2"	600
3"	100
4"	15
5"	1,050

E-3	
DIAMETER (INCHES)	TOTAL LENGTH (FEET)
1 3/4"	705
2 1/2"	515
4"	50
5"	915

F-1	
DIAMETER (INCHES)	TOTAL LENGTH (FEET)
1 3/4"	200
2 1/2"	150
4"	525



RACK	
DIAMETER (INCHES)	TOTAL LENGTH (FEET)
1 3/4"	1,400
2 1/2"	550
4"	500
5"	250

IIA Fire Department Testing

PHONE: (732) 728-0739

FAX: (732) 656-0110

www.industrial-ia.com



2021 HOSE TEST RECORD



All inspections tested to NFPA 1962 Standards

ID	DIA	MAKE	LEN	AGE	LOC	PRESS	P/F	COMMENTS/ ADDL INFO
1000	1 3/4"	Imperial	50	1990	RACK	400	Pass	
1001	1 3/4"	Ponn	50	1995	RACK	400	Pass	
1002	1 3/4"	Premium	50	N/A	E-3	300	Pass	
1003	1 3/4"	MTL	50	2004	RACK	400	Pass	
1004	1 3/4"	Imperial	50	1990	E-3	400	Pass	
1005	1 3/4"	DJ	50	1987	RACK	400	Pass	
1006	1 3/4"	MTL	50	2009	E-3	400	Pass	
1007	1 3/4"	MTL	50	2004	E-3	400	Pass	
1008	1 3/4"	Imperial	50	1990	E-3	400	Pass	
1009	1 3/4"	N/A	50	N/A	E-3	400	Pass	
1010	1 3/4"	MTL	50	2004	E-3	400	Pass	
1011	1 3/4"	MTL	50	2009	RACK	400	Pass	
1012	1 3/4"	Niedner	50	2008	E-3	400	Pass	
1013	1 3/4"	N/A	5	N/A	E-3	400	Pass	
1014	1 3/4"	Jafrib	50	N/A	RACK	300	Pass	
1015	1 3/4"	Premium	50	N/A	E-1	300	Pass	
1016	1 3/4"	Jafrib	50	N/A	RACK	300	Pass	
1017	1 3/4"	Premium	50	N/A	F-1	300	Pass	
1018	1 3/4"	Jafrib	50	N/A	RACK	300	Pass	
1019	1 3/4"	Premium	50	N/A	RACK	300	Pass	
1020	1 3/4"	Jafrib	50	N/A	RACK	300	Pass	
1021	1 3/4"	Premium	50	N/A	F-1	300	Pass	
1022	1 3/4"	Imperial	50	1990	E-3	400	Pass	
1023	1 3/4"	Premium	50	N/A	E-3	300	Pass	
1024	1 3/4"	Jafrib	50	N/A	RACK	300	Pass	
1025	1 3/4"	Premium	50	N/A	E-3	300	Pass	



ID	DIA	MAKE	LEN	AGE	LOC	PRESS	P/F	COMMENTS/ ADDL INFO
1026	1 3/4"	MTL	50	2009	E-3	400	Pass	
1027	1 3/4"	Jafrib	50	N/A	RACK	300	Pass	
1028	1 3/4"	Premium	50	N/A	E-1	300	Pass	
1029	1 3/4"	Premium	50	N/A	F-1	300	Pass	
1030	1 3/4"	Premium	50	N/A	F-1	300	Pass	
1031	1 3/4"	Premium	50	N/A	F-1	300	Fail	
1032	1 3/4"	Premium	50	N/A	F-1	300	Fail	
1033	1 3/4"	Jafrib	50	N/A	RACK	300	Pass	
1034	1 3/4"	Jafrib	50	N/A	RACK	300	Pass	
1035	1 3/4"	Jafrib	50	N/A	RACK	300	Pass	
1036	1 3/4"	Jafrib	50	N/A	RACK	300	Pass	
1037	1 3/4"	Niedner	50	2016	RACK	300	Pass	
1038	1 3/4"	Niedner	50	2016	RACK	300	Pass	
1039	1 3/4"	HWH	50	2016	RACK	300	Pass	
1040	1 3/4"	Niedner	50	2016	RACK	300	Pass	
1041	1 3/4"	Niedner	50	2016	RACK	300	Pass	
1042	1 3/4"	Jafrib	50	N/A	RACK	300	Pass	
1043	1 3/4"	Jafrib	50	N/A	RACK	300	Pass	
1045	1 3/4"	Jafrib	50	N/A	RACK	300	Pass	
1046	1 3/4"	Jafrib	50	N/A	RACK	300	Pass	
1047	1 3/4"	Premium	50	N/A	RACK	300	Pass	
1048	1 3/4"	HWH	50	2016	RACK	300	Pass	
1049	1 3/4"	Ponn	50	1985	E-3	300	Pass	
1050	1 3/4"	Ponn	50	1985	E-3	300	Pass	
1051	1 3/4"	Premium	50	N/A	E-1	300	Pass	
1052	1 3/4"	Premium	50	N/A	RACK	300	Pass	
1053	1 3/4"	NAFH	50	2021	E-1	400	Pass	
1054	1 3/4"	NAFH	50	2020	E-1	400	Pass	
1055	1 3/4"	NAFH	50	2019	E-1	400	Pass	
1056	1 3/4"	NAFH	50	2020	E-1	400	Pass	
1057	1 3/4"	NAFH	50	2021	E-1	400	Pass	
1058	1 3/4"	NAFH	50	2020	E-1	400	Pass	
1059	1 3/4"	NAFH	50	2019	E-1	400	Pass	
1060	1 3/4"	NAFH	50	2020	E-1	400	Pass	
1061	1 3/4"	NAFH	50	2021	E-1	400	Pass	
1062	1 3/4"	NAFH	50	2019	E-1	400	Pass	
1063	1 3/4"	NAFH	50	2020	E-1	400	Pass	
1064	1 3/4"	NAFH	50	2020	E-1	400	Pass	
1065	1 3/4"	NAFH	50	2021	E-1	400	Pass	
1066	1 3/4"	NAFH	50	2020	E-1	400	Pass	
1067	1 3/4"	NAFH	50	2019	E-1	400	Pass	
1068	1 3/4"	NAFH	50	2020	E-1	400	Pass	
2500	2 1/2"	Key	50	1999	E-3	300	Pass	
2501	2 1/2"	Key	50	1999	E-3	300	Pass	
2502	2 1/2"	Key	50	1999	E-3	300	Pass	



ID	DIA	MAKE	LEN	AGE	LOC	PRESS	P/F	COMMENTS/ ADDL INFO
2503	2 1/2"	Jafrib	50	2014	E-3	300	Pass	
2504	2 1/2"	Jafrib	50	2014	E-3	300	Pass	
2505	2 1/2"	Jafrib	50	2014	E-3	300	Pass	
2506	2 1/2"	Key	50	1999	E-3	300	Pass	
2507	2 1/2"	Key	50	1999	E-3	300	Pass	
2508	2 1/2"	Jafrib	50	2014	E-3	300	Pass	
2509	2 1/2"	Key	50	2000	E-3	300	Pass	
2510	2 1/2"	N/A	15	N/A	E-3	300	Pass	
2511	2 1/2"	Key	50	2000	RACK	300	Pass	
2512	2 1/2"	NAFH	50	2016	RACK	300	Pass	
2513	2 1/2"	NAFH	50	2016	RACK	300	Pass	
2514	2 1/2"	NAFH	50	2016	RACK	300	Pass	
2515	2 1/2"	Imperial	50	N/A	F-1	300	Pass	
2516	2 1/2"	Key	50	2000	F-1	300	Pass	
2517	2 1/2"	Key	50	2000	F-1	300	Pass	
2518	2 1/2"	NAFH	50	2016	RACK	300	Pass	
2519	2 1/2"	Key	50	1999	RACK	300	Pass	
2520	2 1/2"	Key	50	1999	RACK	300	Pass	
2521	2 1/2"	Imperial	50	N/A	E-1	300	Pass	
2522	2 1/2"	Premium	50	N/A	E-1	300	Pass	
2523	2 1/2"	Imperial	50	N/A	E-1	300	Pass	
2524	2 1/2"	Premium	50	N/A	E-1	300	Pass	
2525	2 1/2"	N/A	50	N/A	E-1	300	Pass	
2526	2 1/2"	DJ	50	1980	RACK	300	Pass	
2527	2 1/2"	Imperial	50	N/A	E-1	300	Pass	
2530	2 1/2"	Boston	50	N/A	RACK	300	Pass	
2531	2 1/2"	Niedner	50	2001	E-1	400	Pass	
2532	2 1/2"	Niedner	50	2001	E-1	400	Pass	
2533	2 1/2"	Niedner	50	2001	E-1	400	Pass	
2534	2 1/2"	Niedner	50	2001	E-1	400	Pass	
2535	2 1/2"	Niedner	50	2001	E-1	400	Pass	
2536	2 1/2"	Niedner	50	2001	E-1	400	Pass	
2537	2 1/2"	Niedner	50	2001	RACK	400	Pass	
2538	2 1/2"	Niedner	50	2001	RACK	400	Pass	
3000	3"	DJ	50	1986	E-1	300	Pass	
3001	3"	DJ	50	1986	E-1	300	Fail	
3002	3"	DJ	50	1986	E-1	300	Pass	
4000	4"	Jaflite	100	N/A	F-1	200	Pass	
4001	4"	Jafrib	100	N/A	F-1	200	Pass	
4002	4"	Kocheck	100	2012	F-1	250	Pass	
4003	4"	Kocheck	100	2010	F-1	250	Pass	
4004	4"	Kocheck	100	2014	F-1	250	Pass	
4005	4"	Kocheck	25	2012	F-1	250	Pass	
4007	4"	Kocheck	100	2014	RACK	250	Pass	
4008	4"	Jaflite	100	N/A	RACK	200	Pass	



ID	DIA	MAKE	LEN	AGE	LOC	PRESS	P/F	COMMENTS/ ADDL INFO
4009	4"	Jaflite	100	N/A	RACK	200	Pass	
4010	4"	Jafrib	100	N/A	RACK	200	Fail	
4011	4"	N/A	100	N/A	RACK	200	Pass	
4013	4"	Jaflite	100	N/A	RACK	200	Pass	
4015	4"	Kocheck	50	2012	E-3	200	Pass	
4017	4"	N/A	15	N/A	E-1	200	Pass	
5000	5"	Jaflite	100	2006	E-3	300	Pass	
5001	5"	Jaflite	100	2006	E-3	300	Pass	
5002	5"	Jaflite	100	2006	E-3	300	Pass	
5003	5"	Jaflite	100	2006	E-3	300	Pass	
5004	5"	Jaflite	100	2006	E-3	300	Pass	
5005	5"	Snaptime	100	1989	E-3	200	Pass	
5006	5"	Key	100	2001	E-3	200	Pass	
5008	5"	Angus	100	N/A	E-3	200	Pass	
5009	5"	Snaptime	100	1989	E-3	200	Fail	
5010	5"	NAFH	15	2018	E-3	300	Pass	
5011	5"	NAFH	35	2018	E-3	300	Fail	
5012	5"	Key	100	2001	E-3	200	Pass	
5013	5"	Jaflite	100	2007	E-1	300	Pass	
5014	5"	Jaflite	100	2007	E-1	300	Pass	
5015	5"	Jaflite	100	2006	E-1	300	Pass	
5016	5"	Jaflite	100	2014	E-1	300	Pass	
5017	5"	Jaflite	100	2014	E-1	300	Pass	
5018	5"	NAFH	100	2016	E-1	300	Pass	
5019	5"	NAFH	100	2016	E-1	300	Pass	
5020	5"	NAFH	100	2016	E-1	300	Pass	
5021	5"	Key	100	2013	E-1	300	Pass	
5022	5"	NAFH	100	2016	E-1	300	Pass	
5023	5"	Key	50	2012	RACK	300	Pass	
5024	5"	NAFH	35	2018	E-1	300	Pass	
5025	5"	NAFH	15	2018	E-1	300	Pass	
5026	5"	Key	100	2002	RACK	200	Pass	
5027	5"	Key	100	2000	RACK	200	Pass	
		Total Hose Feet Tested	8,860					

"No Test" lengths are not included in the total feet invoiced

* 1987 and older hose is failed by NFPA standards, regardless of passing hydrostatic testing